


- NOTES:**
1. MINIMUM 4" BACKFLOW, METER & PRESSURE REDUCING VALVE VAULT WITH BYPASS. MAY BE USED AS A STANDARD FOR OTHER METERING AND FLOW CONTROL APPLICATIONS.
 2. FOR 8" OR LARGER PRV/FIRE FLOW VALVE VAULT--HORIZONTAL ALIGNMENT FOR SECTION A-A.

	TOWN OF MILTON	
	PUBLIC WORKS DEPARTMENT	
SCALE: NTS	DATE: FEB. 2008	
DRAWING # : 24	DRAWN BY: FA&A	
TYPICAL METER / VALVE VAULT		